

IEC**IECEE**

®

™

Ref. Certif. No.

CN65812

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Fuse-link for the Protection of Semiconductor Device

Name and address of the applicant

Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang
Province, P.R.China

Name and address of the manufacturer

Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang
Province, P.R.China

Name and address of the factory

Zhejiang Tengen Electric Co.,Ltd.
No.332 Liule Road, Liushi Town, Yueqing City, Zhejiang
Province, P.R.China*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

Un:DC1500V,DC1200V,DC1000V,DC750V;In:63A,80A,100A,
125A,160A,200A,250A,300A,315A,350A,400A,450A,500A,5
50A, 630A,700A,800A,900A,1000A,1100A,1250A;I1:
250kA;aR.

Trademark (if any)

TENGEN

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

TGRS3Z-3ETS,TGRS3Z-3ETM,TGRS3Z-3EQS,TGRS3Z-3E
QM;

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60269-1:2006,IEC 60269-1:2006/AMD1:2009, IEC
60269-1:2006/AMD2:2014;IEC 60269-4:2009, IEC
60269-4:2009/AMD1:2012, IEC 60269-4:2009/AMD2:2016

As shown in the Test Report Ref. No. which forms part of this Certificate

03601-A-23CB0183-S

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.


Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: May.13,2024

Signature:



Xie ZhaoXu

